



Product Service

# CERTIFICATE

No. B 032487 0006 Rev. 00

**Holder of Certificate:** **Fabricación de Material Eléctrico, S.A. (Famatel)**  
P. I. El Pla  
Avda. del Pla 11  
08185 Lliçà de Vall  
SPAIN

**Production Facility(ies):** 097708  
**Certification Mark:**



**Product:** **Sockets**  
**Model(s):** **2165**  
**Parameters:** Rated voltage: 250V~  
Rated current: 16A  
Protection class: I  
Degree of protection: IP54  
Method of connecting the cable: Rewirable  
Number of poles: 2-pole with earthing contact  
Kind of construction: DIN 49440-2-D

**Tested according to:** DIN VDE 0620-1:2016/A1:2017  
DIN VDE 0620-2-1:2016/A1:2017

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 704102068302-00  
**Valid until:** 2026-01-19  
**Date,** 2021-01-20

( Jie Zhu )

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT