

CERTIFICATE

Issued to:
Applicant:
Fabricación de Material Eléctrico, S.A.
C/Vapor 12-14 (Poligono Industrial La Ferreria)
08110 Montcada I Reixac, Spain

Product : Fixed socket-outlet
Trade name(s) : FME
Type(s)/model(s) : 2301

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard IEC 60884-1:2002, IEC 60884-1:2002/A1:2006, IEC 60884-1:2002/A2:2013, UNE 20315-1-1:2017 and UNE 20315-1-2:2017
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 6057594
- the licensee is registered with the number 43117


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 19 March 2020 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 31-113051

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



H.R.M. Barends
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Fixed socket-outlet
Trade name(s)	: FME
Type(s)/model(s)	: 2301
Rated current	: 16 A
Rated voltage	: 250 V~
Degree of protection	: IP20
Earthing	: With side earthing contact
Design	: Rewirable, with Pillar terminals
Standard sheet	: C2a of UNE 20315-1-2
Certification mark	: Complies with the requirements
Description	: Body of thermoplastic

TESTS**Test requirements**

IEC 60884-1:2002
IEC 60884-1:2002/A1:2006
IEC 60884-1:2002/A2:2013
UNE 20315-1-1:2017
UNE 20315-1-2:2017

Test result

The test results are laid down in DEKRA test file 606434100.

Additional information

The list of components is laid down at test report 6064341.50.

Conclusion

The examination proved that all requirements were met.

Factory location

The factory location is registered with the number 42848.